

| | | | | | | | |
|--|--|---|--|---|--|---|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | | 1. CONTRACT ID CODE | | PAGE OF PAGES 1 5 | |
| 2. AMENDMENT/MODIFICATION NO. 0001 | | 3. EFFECTIVE DATE 02 DEC 99 | | 4. REQUISITION/PURCHASE REQ. NO. | | 5. PROJECT NO. (If applicable) | |
| 6. ISSUED BY CODE | | 7. ADMINISTERED BY (If other than Item 6) CODE | | 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) US ARMY ENGINEER DISTRICT, FORT WORTH ATTN: CESWF-CT (RM 2A19) PO BOX 17300 FORT WORTH, TX 76102-0300 | | 9A. AMENDMENT OF SOLICITATION NO. DACA63-00-B-0001 9B. DATED (SEE ITEM 11) 8 NOVEMBER 1999 10A. MODIFICATION OF CONTRACTS/ORDER NO. 10B. DATED (SEE ITEM 13) | |
| CODE | | FACILITY CODE | | 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers tended. | | | | <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not ex- | | | |
| Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. | | | | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | | | | |
| <input checked="" type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. <input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). <input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: <input type="checkbox"/> D. OTHER (Specify type of modification and authority) | | | | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office. | | | | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The Solicitation for STUDENT DORMITORY 3226/3227, GOODFELLOW AIR FORCE BASE, SAN ANGELO, TEXAS, is amended as follows: See Continuation Sheet. | | | | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | | | |
| 15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign) | | 15C. DATE SIGNED | | 16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer) | | 16C. DATE SIGNED | |
| NSN 7540-01-152-8070 PREVIOUS EDITION UNUSABLE | | | | 30-105-02 STANDARD FORM 30 (REV. 10-83) Prescribed by GSA FAR (48 CFR) 53.243 | | USAPPCV1.00 | |

Item 14 Continued

a. **Standard Form 1442, Item 13.A- Change the bid opening time and date from “2 p.m. local time 8 December 1999” to “2 p.m. local time 21 December 1999”.**

b. Bidding Schedule – Replace the Bidding Schedule with the attached new Bidding Schedule bearing the notation “ACCOMPANYING AMENDMENT NO. 0001 TO SOLICITATION NO. DACA63-00-B-0001”.

c. Specifications -

- (1) Section 08110, Page 2, paragraph 1.2 SUBMITTALS – Delete entirely “SD-14 Samples Steel Doors and Frames; FIO. Manufacturer’s standard color samples of factory applied finishes.”
- (2) Section 08110, Page 2, paragraph 1.3 DELIVERY AND STORAGE – Delete the first sentence entirely and replace with the following – “During shipment, welded type frames shall be strapped together in pairs with heads at opposite ends, or shall be provided with temporary spreaders at the bottom of each frame.”
- (3) Section 08110, Page 2, paragraph 2.1 DOORS AND FRAMES – After the first sentence, add a new sentence as follows – “Door frames shall be welded with joints filled and ground smooth.”
- (4) Section 08110, Page 3 paragraph 2.6 FACTORY FINISH – Delete both sentences entirely and add a new sentence as follows – “Doors and frames shall be factory primed.”
- (5) Section 06650, Page 6, paragraph 3.1.1 Fastening - Delete the second sentence.

d. Drawings

- (1) Sequence No. 4 (Sheet G-003) –
 - (a) On the BASE BID diagram, show the north-south troopwalk from the front parking area to the building. The north-south troopwalk shall be included in the Base Bid. On the BID OPTION 1 and BID OPTION 2 diagrams, show the troopwalk for information only.
 - (b) Delete OPTION 7 entirely.
 - (c) Delete OPTION 8 entirely.
 - (d) Delete OPTION 10 entirely.
- (2) Sequence No. 12 (Sheet C-103) –
 - (a) Show the north-south troopwalk from the front parking area to the building, as shown on Sequence No. 15 (Sheet C-106). Delete the notation “OPTION 10”.

- (3) Sequence No. 13 (Sheet C-104) –
 - (a) Show the north-south troopwalk from the front parking area to the building, as shown on Sequence No. 15 (Sheet C-106). Delete the notation “OPTION 10”.
- (4) Sequence No. 14 (Sheet C-105) –
 - (a) Show the north-south troopwalk from the front parking area to the building, as shown on Sequence No. 15 (Sheet C-106). Delete the notation “OPTION 10”.
- (5) Sequence No. 15 (Sheet C-106) –
 - (a) At detail mark 8/C-502, delete the notation “OPTION 10”.
- (6) Sequence No. 18 (Sheet C-109) –
- (7) (a) At detail mark 8/C-502, delete the notation “OPTION 10”.
- (8) Sequence No. 30 (Sheet C-502) –
 - (a) At detail 8/C-502, delete the “& 10” from the title.
 - (b) At detail A/C-502, delete the “& 10” from the title.
 - (c) Delete detail 17/C-502 SECTION AT ENTRANCE – OPTION 7.
 - (d) Delete the overprint of the KEY PLAN in the lower right corner.
- (9) Sequence No. 33 (Sheet C-505) –
 - (a) At 4/C-103 SCREENED DUMPSTER PAD, add two PIPE GUARDS at the rear of the dumpster pad centered 300 mm from the back screen and 600 mm from each side. Add detail notation 10/C-505.
 - (b) At 4/C-103 SCREENED DUMPSTER PAD, the PIPE GUARDS shall be centered 300 mm from the screen and centered in line with the screen support on each side.
- (10) Sequence No. 34 (Sheet L-101) –
 - (a) Delete NOTE 9 entirely.
- (11) Sequence No. 103 (Sheet A-601) –
 - (a) On the DOOR SCHEDULE, change the door frames for nnnB, nnnC and nnnD to be HM (hollow metal/steel). Note: All door frames shall be galvanized, as specified.)

(12) Sequence No. 107 (Sheet A-605) –

- (a) On the DOOR SCHEDULE, change all of the door frames to be HM (hollow metal/steel). Note: All door frames shall be galvanized, as specified.)

(13) Sequence No. 110 (Sheet S-101) –

- (a) Add 2/S-101 SECTION to the north side of the north wing.
- (b) Add 2/S-101 SECTION to the east side of the south wing.
- (c) Add 2/S-101 SECTION to the north side of the support area between column grid N13 and C1. (Note that the swale continues around the curve to the east.)
- (d) Add 2/S-101 SECTION to the east side of the support area between column grid SN and CA. (Note that the swale continues around the curve to the north.)
- (e) Clarification: The Administration Building (Option 3) does not have an under floor access space.

(14) Sequence No. 111 (Sheet S-102) –

- (a) Change note to read “WALKWAY SLAB JOINTS SPACED AT THIRD POINT (TYP)” in two places.

(15) Sequence No. 112 (Sheet S-103) –

- (a) Change note to read “WALKWAY SLAB JOINTS SPACED AT THIRD POINT (TYP)” in two places.

(16) Sequence No. 123 (Sheet S-114) –

- (a) Change note to read “WALKWAY SLAB JOINTS SPACED AT THIRD POINT (TYP)” in two places.

(17) Sequence No. 126 (Sheet S-117) –

- (a) Change note to read “WALKWAY SLAB JOINTS SPACED AT THIRD POINT (TYP)” in two places.

(18) Sequence No. 129 (Sheet S-120) –

- (a) Delete the north-south notation “GB-8” between grid lines 1-2 and E-D.2.
- (b) At the dashed line and note FLR. GRADING DIFFERENTIAL LINE, which is the location of the aluminum and glass storefront, add a slope both ways in the slab from the dashed line to the outside edge of the walk. Note: The entire area of slab S-2 (two locations) is supported on void forms. GB-8 in two locations, GB-10 and GB-12 shall remain the same except the slab above them is sloped to align with the edge of the walk.

(19) Sequence No. 131 (Sheet S-122) –

- (a) On 1/S-122 SECTION, the width of the turn down beam at the edge of the walk shall be 178 mm to match the dimension as shown on Sequence No. 129 (Sheet S-120) 1/S-120 FOUNDATION PLAN – ADMINISTRATION BUILDING.
- (b) On 1/S-122 SECTION, the spacing for the dowels on the walk shall be 600 mm.
- (c) On 1/S-122 SECTION, reinforcing bars shall be #10 spaced at 250 each way.

(20) Sequence No. 137 (Sheet S-302) –

- (a) In 7/S-302 delete the void forms and the precast concrete retainers.

(21) Sequence No. 138 (Sheet S-303) – Clarifications:

- (a) 1/S-303 is correct in that the slope of the crawl space extends to the outer grade beam.
- (b) See Sequence 110 (Sheet S-101) 1/S-101 UNDER FLOOR ACCESS SPACE PLAN for additional information on the extent and limits of the crawl space under the dormitory wings and the center support building.
- (c) Note that the void forms are required only under the walkways around the dormitory wings. The sidewalk around the Administration Building is a non-structural slab, therefore does not require the void forms.
- (d) 7/S-303 is applicable at pier C1/NB in 1/S-104 FOUNDATION PLAN – SUPPORT
- (e) 7/S-303 is applicable at pier NB offset between C4 and C5 in 1/S-104 FOUNDATION PLAN – SUPPORT with attention to a note on the right side upper part of the detail stating “NO VOID FORMS IN SUPPORT AREA” and a note on the right side lower part of the detail with an arrow to the slope stating “IN SUPPORT BUILDING”.

STUDENT DORMITORY

Building 3226 /3227

GOODFELLOW AIR FORCE BASE

San Angelo, Texas

SOLICITATION NO. DACA63-00-B-0001

BIDDING SCHEDULE

| Item No. | Description | Estimated Quantity | Unit | Unit Cost | Estimated Amount |
|-----------------------|--|-----------------------|------|--------------|---------------------|
| BASE BID: | All work required by the plans and specifications for the construction of the Student Dormitory <u>excluding</u> all Options. | | | | |
| 0001 | Student Dormitory building complete (including all utilities to a line 1524 mm (5 feet) outside the building exclusive of all work listed separately and excluding the landscaping and irrigation adjacent to the building within the limits of 1524 mm (5 feet)). | Job | Sum | *** | \$ _____ |
| 0002 | Drilled Piers | | | | |
| 0002A | 450 mm Drilled Piers | 132 | M | \$ _____ | \$ _____ |
| 0002B | 600 mm Drilled Piers | 258 | M | \$ _____ | \$ _____ |
| 0002C | 750 mm Drilled Piers | 156 | M | \$ _____ | \$ _____ |
| 0002D | 900 mm Drilled Piers | 300 | M | \$ _____ | \$ _____ |
| 0002E | 1050 mm Drilled Piers | 96 | M | \$ _____ | \$ _____ |
| 0003 | All exterior work beyond a line 1524 mm (5 feet) outside of the building line (inclusive of all earthwork, utilities, curb and gutter, paving, walkways, (am#1) north-south troopwalk from the front parking area to the building, hardscape plaza at juncture of the buildings, landscaping and irrigation [and also including landscaping and irrigation adjacent to the building within the limits of 1524 mm (5 feet) not included in item 0001 above], and all other work not listed separately). | Job | Sum | *** | \$ _____ |
| TOTAL BASE BID | | | | | \$ _____ |

OPTIONS Each Bid Option shall be a separate price that will then be added to the Base Bid.

0004 **Option 1:**

0004A All work required by the drawings and specifications for the complete construction of six (6) additional student rooms in a 3-story configuration in the North wing of the dormitory, exclusive of all work listed separately. This option 1 will increase the number of student rooms from 44 to 50 in the north wing of the dormitory.

| | Job | Sum | *** | \$ |
|--------|-----------------------|-----|------|----|
| 0004B | Drilled Piers | | | |
| 0004BA | (am#1) | | | |
| 0004BB | 900 mm Drilled Piers | 12 | M \$ | \$ |
| 0004BC | 1050 mm Drilled Piers | 6 | M \$ | \$ |

TOTAL OPTION 1 \$

0005 **Option 2:**

0005A All work required by the drawings and specifications for the complete construction of six (6) additional student rooms in a 3-story configuration in the South wing of the dormitory, exclusive of all work listed separately. This option 2 will increase the number of student rooms from 44 to 50 in the south wing of the dormitory.

| | Job | Sum | *** | \$ |
|--------|-----------------------|-----|------|----|
| 0005B | Drilled Piers | | | |
| 0005BA | (am#1) | | | |
| 0005BB | 900 mm Drilled Piers | 12 | M \$ | \$ |
| 0005BC | 1050 mm Drilled Piers | 6 | M \$ | \$ |

TOTAL OPTION 2 \$

0006 **Option 3:**

0006A All work required by the drawings and specifications for the complete construction of the Administration Building (including all utilities to a line 1524 mm (5 feet) outside the building, exclusive of all work listed separately and excluding the landscaping and irrigation adjacent to the building within the limits of 1524 mm (5 feet)).

| | Job | Sum | *** | \$ |
|--------|-----------------------------|-----|------|----|
| 0006B | Drilled Piers | | | |
| 0006BA | 457 mm Drilled Piers (am#1) | 24 | M \$ | \$ |
| 0006BB | 600 mm Drilled Piers | 6 | M \$ | \$ |
| 0006BC | 750 mm Drilled Piers | 162 | M \$ | \$ |
| 0006BD | 1050 mm Drilled Piers | 6 | M \$ | \$ |

ACCOMPANYING AMENDMENT NO. 0001 TO SOLICITATION NO. DACA63-00-B-0001

Solicitation No. DACA63-00-B-0001

0006C All exterior work beyond a line 1524 mm (5 feet) outside of the building line (inclusive of all earthwork, utilities, walkways, landscaping and irrigation related to the option [and also including landscaping and irrigation adjacent to the building within the limits of 1524 mm (5 feet) not included in item 0006 above], and all other work not listed separately) (am#1) and deleting the Base Bid costs for the north-south troopwalk from the front parking area to the building.

| | | | | | |
|--|-----|-----|-----|----|-------|
| | Job | Sum | *** | \$ | _____ |
|--|-----|-----|-----|----|-------|

TOTAL OPTION 3 \$ _____

0007 **Option 4:** All work required by the drawings and specifications for a different development of the site to provide two-way roadways and 90-degree parking, including all variations in site work for grading, drainage, landscaping and irrigation as applicable to this option (am#1) and deleting the costs for the arrangement included in the Base Bid.

| | | | | | |
|--|-----|-----|-----|----|-------|
| | Job | Sum | *** | \$ | _____ |
|--|-----|-----|-----|----|-------|

0008 **Option 5:** All work required by the drawings and specifications for the additional underground irrigation system and landscaping on the eastern (back) part of the building site.

| | | | | | |
|--|-----|-----|-----|----|-------|
| | Job | Sum | *** | \$ | _____ |
|--|-----|-----|-----|----|-------|

0009 **Option 6:** Not used (item deleted).

0010 **Option 7:** (am#1) deleted.

0011 **Option 8:** (am#1) deleted

0012 **Option 9:** All work required by the drawings and specifications to rework the existing Troopwalk between the two driveways to be exposed aggregate concrete with brick paver edging (am#1) and deleting the Base Bid costs for extending the existing Troopwalk to the new east driveway from Apache Trail.

| | | | | | |
|--|-----|-----|-----|----|-------|
| | Job | Sum | *** | \$ | _____ |
|--|-----|-----|-----|----|-------|

0013 **Option 10:** (am#1) deleted

TOTAL BID INCLUDING BASE BID AND OPTIONS 1 THRU \$ _____
(am#1) 5 AND 9

BIDDING SCHEDULE (cont)

NOTES:

1. ARITHMETIC DISCREPANCIES (EFARS 14.407-2)

(a) For the purpose of initial evaluation of bids, the following will be utilized in resolving arithmetic discrepancies found on the face of the bidding schedule as submitted by bidders:

- (1) Obviously misplaced decimal points will be corrected;
- (2) In case of discrepancy between unit price and extended price, the unit price will govern;
- (3) Apparent errors in extension of unit prices will be corrected; and
- (4) Apparent errors in addition of lump-sum and extended prices will be corrected.

(b) For the purpose of bid evaluation, the Government will proceed on the assumption that the bidder intends his bid to be evaluated on the basis of the unit prices, totals arrived at by resolution of arithmetic discrepancies as provided above and the bid will be so reflected on the abstract of bids.

(c) These correction procedures shall not be used to resolve any ambiguity concerning which bid is low.

2. If a modification to a bid based on unit prices is submitted, which provides for a lump sum adjustment to the total estimated cost, the application of the lump sum adjustment to each unit price in the bid schedule must be stated. If it is not stated, the bidder agrees that the lump sum adjustment shall be applied on a pro rata basis to every unit price in the bid schedule.

3. Bidders must bid on all items.

4. Responders are advised that this requirement may be delayed, cancelled or revised at any time during the solicitation, selection, evaluation, negotiation and/or final award process based on decisions related to DOD changes in force structure and disposition of the Armed Forces.

5. For the purpose of this solicitation, the word "item" shall be considered to mean "schedule" as used in Provision 52.214-0019, CONTRACT AWARD--SEALED BIDDING--CONSTRUCTION, in Section 00100 INSTRUCTIONS, CONDITIONS, AND NOTICES TO BIDDERS.

6. EXERCISE OF OPTIONS (SWDR 715-1-1 (16 January 1996))

The Government reserves the right to exercise the option(s) by written notice to the Contractor either singularly or in any combination for up to 90 calendar days after award of the Base Bid without an increase in the Offeror's Bid Price. Completion of added items shall continue at the same schedule as the Base Bid unless otherwise noted in Section 01000 CONSTRUCTION SCHEDULE, paragraph 1 entitled SCHEDULE.

7. LARGE BUSINESS FIRMS.

Bids from large business firms must comply with FAR Clause 52.219-9 regarding the requirement for submission of a Subcontracting plan. **Failure to submit a Subcontracting Plan at the time of bid opening may result in rejection of bid.** The Fort Worth District subcontracting goals are for specified

percentages of the contractor's total planned subcontract amount to be placed with the following: Small Business 61.2%; Small Disadvantaged Business 9.1%; Women-Owned Small Business 5.0%; and Historically Black Colleges & Universities/Minority Institutions (where applicable) 2.0%; and HUBZone Small Business 0.5%.

8. ABBREVIATIONS

For the purpose of this solicitation, the units of measure are represented as follows:

- a. mm (millimeters)
- b. M (length in linear meters)

END OF BIDDING SCHEDULE